

**OPERATION AND MAINTENANCE SCHEDULE FOR  
PRIVATELY OWNED AND MAINTAINED  
BAYSAVER WATER QUALITY DEVICE**

- a. The BaySaver water quality structure shall be periodically inspected and cleaned to maintain operation and function. The owner shall inspect the BaySaver unit yearly at a minimum, utilizing the BaySaver Inspection/Monitoring Form. Inspections shall be done by using a Grade Stick or similar device. When the sediment depths exceed 2 feet, the unit must be cleaned.
- b. The BaySaver water quality structure shall be checked and cleaned immediately after petroleum spills. The owner shall contact the appropriate regulatory agencies.
- c. The maintenance of the BaySaver unit shall be done using a vacuum truck which will remove the water, sediment, debris, floating hydrocarbons and other materials in the unit. Proper cleaning and disposal of the removed materials and liquid must be followed by the owner.
- d. The inlet and outlet pipes shall be checked for any obstructions at least once every six months. If obstructions are found the owner shall have them removed. Structural parts of the BaySaver unit shall be repaired as needed.
- e. The owner shall retain and make the BaySaver Inspection/Monitoring Forms available the Howard County officials upon their request.