



HOWARD COUNTY, MARYLAND

OFFICE OF PURCHASING

6751 Columbia Gateway Drive, Suite 501, Columbia, MD 21046

ADDENDUM NO. 2
ISSUED January 30, 2017
REQUEST FOR PROPOSAL

RFP NO. 11-2017
ENVIRONMENTAL LANDSCAPING SERVICES

OPENING: FEBRUARY 15, 2017 AT 11:00 A.M.

<https://www.howardcountymd.gov/Departments/County-Administration/Purchasing>

This addendum is hereby made a part of this RFP No. 11-2017.

Questions/Answers

Q: I am unclear about the extended price. Are we totaling the cost of 25 rain gardens and 25 rain barrels? If so, at what size? I get the unit price but I am not sure what to extend it by without knowing size of property/impervious surface we are treating.

A: Assume 25 rain gardens and 25 rain barrels. Rain garden: assume 150 SF rain garden treating 500 SF of 100% impervious surface. Rain barrel: assume 55 gallons.

Q: Along the same lines as the above question- are we following the same parameters set forth by the Cleanscapes 50% reimbursement program in terms of rain garden cubic foot ponding depth minimums based on lot size or would any rain garden sized appropriately for square footage impervious surface available work?

A: Yes; the requirements are the same for this program as the traditional CleanScapes reimbursement and credit program.

Q: In the Contractor's Qualification information- would the Engineering Inspection Service be Howard County Cleanscapes, Rachel Bebee, since we're talking residential rain garden work? Or N/A?

A: The County will be responsible for the inspections; you do not need to complete this portion.

Q: I'm a little confused by the portfolio/qualifications section. In a few areas submissions are requested in a few different ways: The contractors qualification information asks for 5 stormwater projects, most recent but also asks that 3 be more than 2 years old.

A: You are asked to submit a minimum of 5 projects (maximum portfolio not to exceed 25 pages); you may submit more than 5 if you wish. We require that 3 be more than 2 years old to verify that your work has longevity. You may satisfy all of the requirements below with the same portfolio.

All other specifications, terms and conditions remain the same.

Please acknowledge addenda by signing below and returning with the proposal. Failure to acknowledge this addendum may be cause for rejection of the proposal.

All other specifications, terms and conditions remain the same.

Please acknowledge addenda by signing below and returning with the proposal. Failure to acknowledge this addendum may be cause for rejection of the proposal.

ADDENDUM RECEIVED BY:

_____	_____
Company Name	Signature

	Title

blm